


Laboratory Compaction Characteristics of Soil  
Using Standard Effort (12,400 ft-lbf/cu ft)  
ASTM D 698-91, Method C



**Project:** Shopping Center Development

January 31, 2001

**EI Project Number:** 45434

**Client:** Build-Tech Unlimited

**ASTM Specification:** D 698 - 91, Compaction Characteristics of Soil Using Standard Effort

**Sample:** S-1 (Bulk)

**Soil Description:** Reddish 2A Modified Stone

**Maximum Dry Density:** 134.0 pcf

**Optimum Moisture Content:** 7.0%

**As-Received Moisture Content:** 8.2%

